




# Stand-Alone Gas Sensor HCF100



The new **HCF100** is born from the elegance and prestige that has always distinguished **BEINAT S.r.I.** and from the home fitness concept.

The probe is a semiconductor gas detection unit with IP55 protection that, together with one of BEINAT's industrial type Control Units, detects the presence of **TOXIC GASES** such as: **Refrigerant FREON R134a**, **R404A**, **R407C**, **R410**, **R32**, **507** 

The probe is managed by a microprocessor which not only supplies an alarm signal to the control unit connected to it, but also allows execution of a self-diagnosis and therefore an AUTOMATIC CALIBRATION, in order to always have the maximum detection accuracy.

The self-calibration means the probe adapts in harsh and variable temperature environments, avoiding false alarms due to anomalous events.

The probe has a 0  $\div$  999 ppm linear output, conforming to the 4  $\div$  20mA standard.

## Indispensabile instrument for the annual check of the probes Instrument of testing TS1008

To facilitate the reading of the functional parameters of the probe as well as the control of annual operating, the **BEINAT S.r.I.** has built a new portable tester **TS1008**.

The tester allows to read all the data in the memory of the probes eand by serial transmission, it prints the ticket that confirms the testing data.





**Important:** Assembly / maintenance of the appliance must be carried out by qualified personnel and in accordance with applicable laws and regulations.

The manufacturer assumes no responsibility for the use of products that have to comply with particular environmental and / or installation standards.



## Important note

Before connecting the equipment, it is recommended that you read the instruction manual carefully and keep it for future reference. It is also recommended to perform the electrical connections correctly as per enclosed drawings, observing the instructions and the Standards.

N.B. Refer to the documentation in all cases where the symbol is on the side



Installation and user guide

CONFORMITY

EN 50270 Compliant EN 60079-29-1 Installation EN 60079-29-2 Reports issued by TUV Italia

You

## **Precautions**


CHECK the integrity of the unit after having removed it from the box.

Check that the data written on the box correspond to the type of gas used.

When doing the electrical connections, follow the drawing closely.

Any use of the detector for purposes other than the intended one is considered improper, and as a result of which **BEINAT S.r.I.** therefore disclaims any responsibility for possible damages caused to people, animals or objects.

**TERMS and EXPECTATIONS**: The installation of the **HCF100** Probe, its ordinary and extraordinary maintenance, every six months, and its out of service removal at the end of the functional life guaranteed by the manufacturer, must be carried out by **authorized or specialized personnel**.



The control unit can be seriously damaged as it is not waterproof either when immersed in water or exposed to high levels of humidity.

#### Do not drop it.

Heavy knocks or falls during transportation or installation can damage the appliance.

Avoid abrupt temperature fluctuations.

Sudden temperature variations can cause condensation and the control unit could work poorly.

#### Cleaning

Never clean the device with chemical products. If necessary, wash with a moist cloth.

## **Technical Specifications**

Power supply	12÷24 VDC ==± 10%
Power demand	
Relay switching alarm	
Sensor	Semiconductor
Sensor according to the type of gas, ON REQUEST	Refrigerant FREON
Measuring range	
Detector accuracy	
Response Time	
Calibrated using	
Auto zero procedure	
Warm-up time	
Analog output signal	
Thirding Sutput Signal	1720 MM Standard tolordrice
Functioning humidity	0-90% non condensed
Functioning temperature	10°C to +50°C
Control units usable BX444-Mc, BX449F, GS100M, BX180	
Max. distance between probe and unit	
Cable diameter for connecting probe	
Connection: The cable of connection of the probe must not be	
•	be installed together with the power cables.
Otherwise, make sure to use a shielded cable	ADC
Probe's body material	
External degree of protection	
Size	78x114x58 mm

HCF100 Technical Features						
Code	Type of Gas	Sensor	Working range	Temperature		
HCF100fre1	Freon R134a	Semiconductor	999 ppm	-20+60°C		
HCF100fre2	Freon R404A	Semiconductor	999 ppm	-20+60°C		
HCF100fre3	Freon R407C	Semiconductor	999 ppm	-20+60°C		
HCF100fre4	Freon R410A	Semiconductor	999 ppm	-20+60°C		
HCF100fre5	Freon R32	Semiconductor	999 ppm	-20+60°C		
HCF100fre6	Freon 507	Semiconductor	999 ppm	-20+60°C		

## WARNING!

The sensor **SEMICONDUCTOR** has a duration that can vary from about 5 to 6 years in clean air. The working temperature of the probe varies from  $-20^{\circ}\text{C}$  to+  $60^{\circ}\text{C}$ .

It must do the test of the detector simulating the gas detection using a pre-calibrated gas spray.  ${\bf N.B.}$ 

The operation test and eventual calibrazine must be performed at least 1 time a year by qualified technician

CONTROLUNITS	MOUNTING	PROBES Max.	DEGREE	PRE	ALARMS	POSITIVE	OPERATING
			protec.	alarms		safety	range
GS100M unit 1 zone	Wall/cabinet	1	IP44	2	1	YES	ΝO
GS300M unit 1 zone	Wall/cabinet	3	IP44	2	1	YES	ΝO
BX444-MC unit 1 zone	Wall/cabinet	4	IP44	2	1	YES	ΝO
BX150 unit 1 zone	Panel	1	IP42	1	1	YES	ΝO
BX180 unit 1 zone	Omega bar DIN	J 1	IP20	1	1	YES	ΝO
BX280 unit 1 zone	Omega bar DIN	J 2	IP20	1	1	YES	ΝO
BX449F unit 1 zone	Omega bar DIN	4	IP20	1	1	YES	ΝO
BX308 unit 1 zone	Omega bar DIN	8	IP20	1	1	YES	YES
BX308/Box unit 1 zone	Wall	8	IP65	1	1	YES	YES
BX316 unit 2 zones	Barra Omega	16	IP20	1	2	YES	YES
BX316/Box unit 2 zones	Wall	16	IP65	1	2	YES	YES
TAKITJ8 * Data Collector	Wall	8	IP65	-	-	-	-


## **MAINTENANCE**



The user periodically (every 6 months) must perform a check of the operation of the control unit by spraying a suitable test gas at the base of the probes connected until the alarm condition is reached.

- · At least once a year make a more accurate check by a specialist technician.
- Disabling the detector must be carried out by qualified personnel.







## Positioning of the Probe


The position of the probe is a crucial factor for a gas detection unit correct functioning. In order to obtain the maximum results from an appliance and minimize the probabilities of false alarms, we recommend to follow this diagram and to keep in mind the following general rules. The remote probe must be located at different heights, according to the type of gas. These heights are:


- 30 cm from the lowest point of the floor in order to detect Heavy Gases: FREON
The probe must not be placed near the following: furnaces, fuel-burning kitchen appliances, fireplaces, ranges, suction fans, and should not be affected by smoke, vapour as these could distort its measurement.
The probe must not be placed away from sources of heat, suction fans, ventilation fans, windows, doors, etc. that can distorting the detection, should be placed away from heat sources and away from aspirators or fans.






## **Detection Diagrams Data**








Page 4

## WARNING

Before connecting to the mains power, ensure the voltage is correct. Carefully follow the instructions and the connections according to Regulations in force, keeping in mind that the signal cables should be laid separate from the power cables.





#### Attention!!

The regulations described in this paragraph must performed be authorized and specialized technician are suceptibile to compromise the safety of the survey.

## If the device does not start up.

Check that the 12 ÷ 24 VDC power is present, and that positive and negative polarity has not been inverted.

## If the Fault LED lights up.

If the fault signal reaches the control unit connected to the probe.


Check that the cables are connected according to the drawing, and that the wire isolation sheath has not been pinched. Check the voltage at the terminals 1-2. It must be higher than 11 VDC and lesser than 25 VDC.

Check the voltage at the terminals 2-3. It must be from a minimum of 0.8 VDC to a maximum of 1.1 VDC

### WARNING.


These measurement should be performed in clean air.

Moreover, this test must be performed only with the probe connected to a control unit, or with a 220 Ohm resistance installed between terminal 2 and terminal 3.



If other problems arise, a specialised and/or authorised technician and/or the Distributor of **BEINAT S.r.l.** should be contacted directly.

## Gas Input Test



The installation of the **HCF100** probe, its ordinary and extraordinary maintenance, and its out of service removal at the end of the functional life guaranteed by the manufacturer, must be carried out by authorized or specialized personnel.

The general test should be performed by issuing gas from a pre-calibrated aerosol within the percentages illustrated on the side.

Important: This test must be carried out at least once a year.

## WARNING! Actions to be taken in case of alarm

## WARNING! Actions to be taken in case of alarm

#### Gas

- 1) Put out all free flames.
- 2) Close the main gas tap or the LPG cylinder tap.
- 3) Do not turn any lights on or off; do not turn on any electrical device or appliance.
- 4) Open windows and doors in order to increase ventilation.
- If the alarm stops, its cause must be found and the relevant consequent measures taken.

If the alarm continues and the cause of gas presence cannot be found or removed, abandon the building and call the emergency services when outside (fire department, distributors, etc.)

IMPORTANT: The operation test should not be carried out with the gas tap as this does not guarantee a sufficient

concentration to activate the general alarm.

#### Warning!!

If you have the following symptoms: vomiting, sleepiness, or else, go to the closest first aid station and inform the operators that you could have been poisoned by **Refrigerant Freon**, or by an excess or deficiency of oxygen





INSURANCE. This device is insured by the SOCIETÀ REALE MUTUA for the PRODUCT'S GENERAL LIABILITY up to a maximum of 1,500,000.00 EURO against damages caused by the device in case of failures in functioning.

WARRANTY. The warranty term is 3 years from manufacturing date, in agreement with the following conditions. The components acknowledged as faulty will be replaced free of charge, excluding the replacement of plastic or aluminium cases, bags, packing, batteries and technical reports.

The device must arrive free of shipment charges to BEINAT S.r.I.

Defects caused by unauthorized personnel tampering, incorrect installation and negligence resulting from phenomena outside normal functioning shall be excluded from the warranty.

BEINAT S.r.l. is not liable for possible damage, direct or indirect, to people, animals, or things; from product

faults and from its enforced suspension of use.





## Sensor

Lo styling è della b & b design

Purchase date:	• • • • • • • •	• • • • •				Stamp	and signat	ure of th	e dealer	
Matricola:	• • • • • • • • •									
The Beinat S.r.l. for functional any time			its products,	reserves	the right	to modify	the technica	features,	aesthetic	and

## BEINATS.r.I.

Via Fatebenefratelli 122/C 10077, S. Maurizio C/se (TO) - ITALY Tel. 011.921.04.84 - Fax 011.921.14.77 http://www.beinat.com

